



Fire Prevention Bureau

102 Remington Street  
Fort Collins, CO 80524

Phone: 970-221-6570

Fax: 970-221-6635

Internet: [www.poudre-fire.org](http://www.poudre-fire.org)

## **Final Test Check Sheet** **Commercial Hood and Duct System**

**Correct Size of Wet Chemical System**

**Appropriate Nozzle and Appliance Arrangement**

**Plenum                      Nozzle**

**Separate Zone on Alarm System (if existing)**

**K Extinguisher within 30 Feet of System**

**Manual Pull Near Means of Egress (at least 20 feet from Hood)**

**4-5                              Feet off Floor**

**Maximum                      Movement of 14 Inches**

**Maximum                      Force of 40 Pounds**

**Makeup Air Shuts Down**

**Gas Shuts Down, and Electrical Shuts Off**

**Ventilation                      Continues or Begins if Off**

**Fusible                        Link**

**Alarm System Activated (if existing)**

**Completion of Paperwork**

**If you have any questions, contact Garnet England at 970-219-8651 or by email at [gengland@poudre-fire.org](mailto:gengland@poudre-fire.org)**