



**Poudre fire
Authority**

Fire Prevention Bureau

102 Remington Street
Fort Collins, CO 80524

Phone: 970-221-6570

Fax: 970-221-6635

Internet: www.poudre-fire.org

Final Test Check Sheet
Sprinkler System

Sprinkler Test

Main Drain Test

Static and Residual Pressures

Tampers

Inspectors

Test

30-40 Seconds to Outside Horn and Strobe

Outside Horn Stops when Flow Stops

Signals Received at Central Station

Riser Inspection

Signage – (rust-proof chains)

Control Valves

Main

Drain

Inspectors

Test Connection

Hydraulic

Information

Fire Riser Room

3”

Sticker for Inside Doors

6” Weather Resistant (OS Door)
(White on Red)

Stability

Expansion Tank (UL Listed)

Sprinkler Box

Appropriate # and Type of Sprinklers

Wrench

200

Pound Test Documentation

Certificate of Completion

If you have any questions, contact Garnet England at 970-219-8651 or by email at gengland@poudre-fire.org